

# **Town of Dover Community Center**

**Building Committee**

- **HVAC System Analysis**
- **Planning Board**

**March 9th, 2021**


# Schematic Design

## Upcoming Meetings

- ✓ Energy Sub-Committee – 3/4
- ✓ Review program with COA - 2/24
- ✓ Review program with Parks & Recreation -2/24
- ✓ Meet with Planning to review Parking Options -3/8

## Milestones

- Feasibility Report
- Mechanical Design
- Structural Design
- Site Design
- Architectural Design
- Cost Estimating Set



# Building a vision Building consensus

1. Major Building Elements for Energy Efficiency
2. HVAC System Analysis
3. Other Energy Systems
4. Planning Board Summary
5. COA Location in 2-Story Option

# Overview of Sustainability Goals

*-from 11/9 BC Presentation*

## Highly Efficient Building Metrics

- LEED – certification or certifiable?
- % savings from Baseline ASHRAE code minimum
- EUI – Energy Use Intensity in kbtu/SF
- Net Zero Energy (Actual or Ready?)
- Carbon Neutrality – No fossil fuels, All Electric
- Water Savings
- Building Envelope – Passive House, etc.

## EUI – Energy Use Intensity

- 30 kbtu/SF – very aggressive goal with to achieve Net Zero Energy
- 50 kbtu/SF – comparable code minimum building systems/envelope



# Existing Energy Use

- 2018-2020 Electric and Oil Bills
- Normalized to account for COVID shut-down in March 2020
- 40,000 gsf existing school building
- Energy Use Intensity (EUI) is per sq. foot for better comparison



Existing




2030 Baseline  
(office)



Current Model  
(office)

# Major Factors in Energy Use

1. Solar Heat Gain /Orientation
2. Insulation
3. Window U-Value
4. Tight Envelope
5. Mechanical System (Heating/Cooling/ Air)



# Insulation

## Building Envelope Factors

**EUI= 27.9**

- **Roof Insulation:**
- **Wall Insulation :**
- **Slab Insulation:**
- **Tight Envelope:**

**Baseline**

**R-30**

**R-20**

**CODE**

**Upgrade**

**R-50**





**R-30**

**Upgraded EUI**

**26.4 -1.3**

**27.2 -0.7**

Baseline Energy 



# Windows

## Building Envelope Factors

**EUI= 27.9**

**Baseline**

**By Option**

**U=.28**

**SHGC=.28**

**Upgrade**

**U=.24**

**SHGC=.21**


**Upgraded EUI**

**27.4**      **-0.3**

**28.4**      **+.5**

- **Orientation:**
- **U-Value:**
- **Solar Heat Gain**

Whole Building EUI Breakdown



# HVAC System Options

# HVAC

## System Option 1 – (Ground Source Heat Pumps)

- Heating and cooling generated centrally with a 50 ton heat recovery chillers that will extract/reject heat to a geothermal well system.
- Estimating 2.25-tons per well, project will require 24 wells.
- Can be combined with electric boiler/chiller to offset peak loads.
- Dedicated distribution piping with a run/standby pump configurations for each system (Condenser Water, Chilled Water and Heating Hot Water)
- Vertical duct risers, distribution ductwork and VAV terminals for control.
- Dedicated Outdoor Air System (DOAS) with Energy Recovery



# HVAC

## System Option 2 – (Air-Source VRF with FCU's & DOAS):

- VRF condensing units coupled with fan coil units for individual zone control.
- Refrigerant distribution will extend from each condensing unit to FCU's throughout.
- Vertical duct risers, distribution ductwork and VAV terminals for control.
- Dedicated Outdoor Air System (DOAS) with Energy Recovery
- Refrigerant distribution will extend from each condensing unit to FCU's throughout.



# HVAC

## System Option 3 – (Package Roof Top Units):

- (2) 12,500 CFM packaged rooftop units
  - DX/electric cooling.
  - Will utilize hot water boiler/coil in lieu of gas furnace.
- Vertical duct risers, distribution ductwork and VAV terminals for control.
- RTU System provides ventilation throughout.
- Hot water (30% glycol) distribution piping.



# HVAC System Matrix

System	GSHP	VRF	RTU
<u>Pro's</u>	<ul style="list-style-type: none"> <li><input type="checkbox"/> Flexibility with range of systems options</li> <li><input type="checkbox"/> More sturdy/reliable</li> <li><input type="checkbox"/> Lower operating cost compared to direct electric</li> <li><input type="checkbox"/> Higher probability of achieving NZE.</li> </ul>	<ul style="list-style-type: none"> <li><input type="checkbox"/> Lower initial cost (installation)</li> <li><input type="checkbox"/> Lower equipment maintenance costs</li> <li><input type="checkbox"/> Flexibility with varying tenant schedules</li> <li><input type="checkbox"/> Metering capabilities for billing</li> <li><input type="checkbox"/> Simple building automation</li> <li><input type="checkbox"/> No central mechanical room</li> <li><input type="checkbox"/> No piping heat loss</li> </ul>	<ul style="list-style-type: none"> <li><input type="checkbox"/> Lower equipment maintenance costs</li> <li><input type="checkbox"/> Flexibility with varying tenant schedules</li> <li><input type="checkbox"/> Equipment is located in one location</li> <li><input type="checkbox"/> Flexibility on future renovations</li> </ul>
<u>Con's</u>	<ul style="list-style-type: none"> <li><input type="checkbox"/> Higher initial cost (installation)</li> <li><input type="checkbox"/> More complicated to operate/repair</li> <li><input type="checkbox"/> Increased maintenance</li> <li><input type="checkbox"/> Advanced building automation</li> <li><input type="checkbox"/> Requires central mechanical room</li> <li><input type="checkbox"/> Location specific (required test wells to determine available capacity)</li> </ul>	<ul style="list-style-type: none"> <li><input type="checkbox"/> Less efficient in cold weather (over/under sizing)</li> <li><input type="checkbox"/> Limitations on pipe runs</li> <li><input type="checkbox"/> Multiple compressors</li> <li><input type="checkbox"/> Potential for refrigerant leaks</li> <li><input type="checkbox"/> Aesthetics of exposed equipment</li> <li><input type="checkbox"/> Rapidly developing/changing VRF technology</li> <li><input type="checkbox"/> Proprietary service requirements</li> <li><input type="checkbox"/> Limitation on future expansion</li> </ul>	<ul style="list-style-type: none"> <li><input type="checkbox"/> Higher initial cost (installation/equipment)</li> <li><input type="checkbox"/> Aesthetics of exposed equipment</li> <li><input type="checkbox"/> Ambient acoustics</li> <li><input type="checkbox"/> Larger distribution systems</li> <li><input type="checkbox"/> Lower energy efficiency</li> <li><input type="checkbox"/> Requires fossil fuel for heating (gas furnace or boiler system)</li> <li><input type="checkbox"/> Requires central mechanical room</li> </ul>





# Relative Energy Models

(Cove.tool)

# HVAC System 1 – Ground Sourced Heat Pump



Baseline Energy [?](#)

[Create Report](#) [Climate Analysis](#)


Whole Building EUI



Office

26.74 kBtu/ft<sup>2</sup>/yr


LEED Points - EAc2 Credit [?](#)



Electricity  
Natural Gas


\$21915.5 /yr  
\$0 /yr

CO2 Reduction %




2030 Baseline  
Emissions  
You Saved  
147.2 Tonne/CO2e/yr  
52.8 Tonne/CO2e/yr  
14 Trucks of Ice/yr [?](#)

Benchmarking Energy



Project not yet updated in DDX

Whole Building EUI Breakdown



# HVAC System 2 – Variable Refrigerant Flow (VRF)



Baseline Energy

[Create Report](#) [Climate Analysis](#)


Whole Building EUI



Education

27.92 kBtu/ft<sup>2</sup>/yr


LEED Points - EAc2 Credit



Electricity  
Natural Gas


\$22884.82 /yr  
\$0 /yr

CO2 Reduction %



2030 Baseline Emissions  
You Saved  
147.2 Tonne/CO2e/yr  
55.2 Tonne/CO2e/yr  
14 Trucks of Ice/yr


Benchmarking Energy



[Update 2030 DDX](#)

Project not yet updated in DDX

Whole Building EUI Breakdown



# HVAC System 3 – Packaged Roof Top



Baseline Energy [?](#)

[Create Report](#) [Climate Analysis](#)


Whole Building EUI



Education

34.19 kBtu/ft<sup>2</sup>/yr


LEED Points - EAc2 Credit [?](#)



Electricity  
Natural Gas

\$28022.85 /yr  
\$0 /yr


CO2 Reduction %



2030 Baseline  
Emissions  
You Saved

147.2 Tonne/CO2e/yr  
67.6 Tonne/CO2e/yr  
12 Trucks of Ice/yr [?](#)


Benchmarking Energy



Update 2030 DDX


Project not yet updated in DDX

Whole Building EUI Breakdown



# HVAC Systems - Cost Benefit

	EUI	Cost \$K
● <b>Ground Sourced Heatpump</b>	27	\$1,820
● <b>Variable Refrigerant (VRF)</b>	28	\$880
● <b>Packaged Rooftop Units (RTUs)</b>	34	\$1,000





# Other Energy Systems

# Electrical

## PhotoVoltaic Array Considerations

- Solar Orientation and Shading Impacts
- Space availability on roof and site


## New Two-Story Building Option

- Demand at 30 kbtu/sfy/yr goal = 136,244 kwh/yr
- Potential production using 6,000 SF roof = 113,530 kwh/yr
- % toward NZE goal = 83%

## Save 1910 Reno Option

- Demand at 30 kbtu/sfy/yr goal = 153,824 kwh/yr
- Potential production using 4,200 SF roof = 79,470 kwh/yr
- % toward NZE goal = 52%
- If no community roof usage, % NZE = 25%

Continue Pursuit? Involve 3<sup>rd</sup> party installer or own panels?




**New Two-Story: 6,000sf**




**Save 1910: 2,000sf + 2,200sf**



# Electrical - Potential PV Areas



Save 1910: 2,000sf + 2,200sf



New Two-Story: 6,000sf



# Emergency Generator

## Warming/ Cooling Center

- Budget currently carrying cost for a 200KW generator
- Pending further design detail, should be able to cover entire building load (with diversification) during an emergency “event”.
- Backing up the entire main service panel has premium cost to generator but savings on distribution and flexibility for uses within building during an “event”
- Diesel fuel storage for an “event” duration of 48hrs will require 1,000 gallon tank.
- Switch to Propane over Diesel will increase size/cost of generator and may limit refueling options





# Planning Board – March 8th

# Zoning Background




**Zoning District: O** (Official or Open Space) *hatching per 1981 Zoning Map*  
Allowed uses: Church, Educational, Farm, Municipal recreational, Municipal

**Dim Requirements:**

- Front Setback: 40ft
- Side Setback: 20ft
- Rear Setback: 0ft?
- Max Height: 35ft, 2.5 stories
- Max. Lot Coverage: 40%

Site Plan Review will be required per §185-40 or Official or Open Space District  
(coordinated with § 185-36 Site Plan Review )



# Zoning Background



**Zoning District: O** (Official of Open Space) *hatching per 1981 Zoning Map*  
Allowed uses: Church, Educational, Farm, Municipal recreational, Municipal

## Bldg Requirements (§ 185-40)

Submit to the Board of Selectmen for review prior to building permit:

- a) Emergency access
- b) Lot size, frontage, yards and heights of buildings.
- c) Vehicle and pedestrian safety
- d) Parking arrangement and the number of parking
- e) Water supply, sewage, and drainage.

**Acoustical considerations:** No Dover noise by-law, best practices

**Light Trespass:** Exterior lights to be specified at Dark Sky compliant and light trespass limited to LEED standard

## Existing Site Plan

## Set back from Springdale

## Main entrance not Accessible

**Lacks plaza/ forecourt @ entry**

## No Drop-off lane

**64 parking spaces**

## **Lacks outdoor activities (except pre-k)**

## Basketball court near neighbor



# Feasibility Site Plan

- Sited close to Springdale
- Plaza/ Forecourt @ entry
- Drop-off lane (bus or cars)
- New plantings at entry
- 65-75 parking spaces (existing @ 64)**
- Outdoor activities : walking, play, garden, gathering
- Patios for exterior/interior flow
- Basketball (half court), keep field space**
- Building lot coverage 8-10%
- Impervious ~ 52%




## Available Parking



On-Site	70 (5 HC)
Springdale	20 (2 HC)
	<hr/>
	90 spaces
Town House:	25
Dover Market	38
7 Whiting Rd.	27
Highway Dept.	45
	<hr/>
	135 spaces
<b>Total Available</b>	<b>225 spaces</b>

# Anticipated Occupancy



Building Code 800

Anticipated Avg. 124

Big Event 180

Dinner	100
Dance Class	20
Flex Room	30
Misc.	30

180 Occupants

Avg. Occupants per car x2.0

Parking by 4 Springdale  
Immediate capacity  
90 spaces  
180 persons

Nearby parking  
125 spaces



# Location of COA Offices (New 2-Story Option)

# Options for Schematic Design

## New 2-Story



First Floor Plan

Second Floor Plan

## Save the 1910




First Floor Plan

Second Floor Plan

# COA Office Location

## Approved Concept Plan




## Evaluation Factors

- ○ ● **COA Office Location:** on Upper Level, needs elevator
- ○ ● **Senior Activities Location:** on Upper Level, needs elevator
- ● ● **Parks & Rec Office:** on Upper Level, remote from entry
- ● ● **Community Room:** on Lower Level, easily accessible
- ● ● **Balanced Upper/Lower:** relatively balanced floors for efficiency
- ● ● **Senior Social Area:** has cohesive area for seniors



# COA Office Location

## Alternate Plan



## Evaluation Factors

- ● ● **COA Office Location:** on Lower Level, easily accessible
- ○ ● **Senior Activities Location:** on Upper Level, needs elevator
- ○ ○ **Parks & Rec Office:** on Upper Level, remote from entry
- ● ● **Community Room:** on Lower Level, easily accessible
- ● ● **Balanced Upper/Lower:** relatively balanced floors for efficiency
- ○ ○ **Senior Social Area:** lacks cohesive area for seniors

