



COLONIAL
Water Company

Paul McGovern
P.G. Construction Management, Inc.
1218 Great Plain Ave.
Needham, MA 02492

Subject: **Red Robin Pastures**

Dear Mr. McGovern:

This is to recap our previous emails regarding the above.

After reviewing the proposed project, we would service the apartments contingent upon the following stipulations.

- Red Robin Pasture will not use CWC water supply for fire suppression. An independent suppression system must be used.
- CWC will monitor strict adherence to 65 gallons per capita per day use of water. This limit would be enforced per unit.
- All units must be individually metered with locations in a separate central mechanical room. CWC will furnish the meters and install them.
- No exterior irrigation will be allowed.
- To service the top floors, an internal pumping system may be necessary. CWC will investigate static pressures in the vicinity and will advise.
- A main extension may be required within County Road. We will advise.

Please do not hesitate to let me know if you have further questions or comments.

Very truly yours,

Don Vaughan
Colonial Water Company

C: Jim Waldron
Bob Gallo