



Dover, MA

Jasmin Farinacci <jfarinacci@doverma.gov>

Dover Salt Shed Amendment

Edward Kornack <ekornack@doverma.gov>
To: Jasmin Farinacci <jFarinacci@doverma.gov>

Thu, Aug 22, 2024 at 12:31 PM

Hi Jasmin

The Fire Department has no concerns with the removal of the old fueling station. We only require a permit/paper trail to let us know the tanks final disposal site when removed and the name of the contractor handling this.

For the new one, The plans I saw include all the requirements we have. The canopy does not have to have a fire suppression system in it. The storage of that amount of fuel may require a special permit from the Town due to the capacity. I assume spill protection will be incorporated into the revised plans also. Please send us a full copy of the proposed fuel island when it is done. If you have any further questions please let me know.

Thanks

Ed Kornack
Dover Fire
781-445-4567

[Quoted text hidden]